

# CONNECTING SENQUIP DEVICES TO CUMULOCITY IOT

## 1. Introduction

This application note details how to integrate Senquip telemetry devices with Cumulocity IoT from Software AG using MQTT static templates. Senquip devices and Cumulocity IoT also support HTTP and other MQTT protocols, but these will not be considered in this application note.

Cumulocity IoT enables full IoT solutions to be created in minutes by anyone who can use everyday office productivity apps. This allows your business to adopt an extremely efficient, low-effort, rapid-refinement, and agile approach to IoT solution creation.

This application note is also available as a video on [YouTube](#).

**Connect:** Connect any “thing” using any protocol over any network using a “plug-and-play” approach.

**Analyse:** Get instant insights from a range of analytics techniques and visualize these in real-time interactive dashboards.

**Integrate:** Embed IoT data into your business applications and orchestrate workflows between them.

MQTT stands for Message Queuing Telemetry Transport and is a lightweight, publish-subscribe network protocol that transports messages between devices. To ease device integration Cumulocity IoT already supports several static templates that can be used by any client to send standard messages to Cumulocity IoT. This application note will make use of static templates that will be implemented using a simple script running on the Senquip device.




Figure 1 - Cumulocity IoT Dashboard

## 2. Device and Cumulocity IoT Configuration

This section outlines how to configure a Senquip device to communicate with Cumulocity IoT over MQTT. It is assumed that the user has created an account on the Senquip Portal to allow device configuration and has an account on Cumulocity IoT. It is always a good idea to upgrade to the [latest Senquip device firmware](#).

Static templates allow devices to send configuration data to specify the capability of the attached device, properties such as hardware and firmware revisions, measurements including position, alarms, and events. Each static template has a defined structure that is documented on the [Cumulocity website](#).

Static templates support automatic creation of devices if they do not exist. When you send data, Cumulocity IoT will automatically create a device for the MQTT Client ID. If you want to create the device on your own, your first message must be the device creation. In this case Cumulocity IoT will create the device from the template.

To setup the MQTT endpoint details, using the Senquip Portal, go to *Settings>Endpoint* and fill in the MQTT section.

<b>Document Number</b> APN0016	<b>Revision</b> 1.1	<b>Prepared By</b> NGB	<b>Approved By</b> NB
<b>Title</b> Connecting Senquip Devices to Cumulocity IoT			<b>Page</b> 3 of 8

## MQTT

MQTT  Enabled

Broker Address

Client ID

Data Topic

Username

Password

[Configure MQTTs](#)

Figure 2 - Example MQTT configuration for Cumulocity IoT

The Broker Address is of the format `mqtt.cumulocity.com` and will depend on your region and the type of account. The Port is 1883 and so the Broker Address becomes `mqtt.cumulocity.com:1883`. If left blank, the Client ID will default to the Senquip device ID. To use static templates, you need to publish the MQTT messages to the Topic `s/us`. In this case, we will be publishing MQTT messages within the script and so you can leave the Data Topic blank.

When you register for an account on Cumulocity IoT, you will receive a tenant ID. Your username will be formed from the tenant ID and username in the format `<tenantID/username>`. In this case the tenant ID is `t123456789` and the username is `demo@senquip.com` and so the username is `t123456789/demo@senquip.com`. The Password is the password for you Cumulocity IoT account.

Lastly, unselect the *Use Senquip Data Format* option to stop standard Senquip messages being sent to the Cumulocity portal. In the next section, we will create custom messages specific to the platform.

### Data Endpoints

- Configuration via Senquip Portal  Enabled
- Send Data to Senquip Portal  Enabled
- Offline Buffer  Enabled
- Add Formatted Time  Enabled
- Report Network Info  Enabled
- Use Senquip Data Format  Enabled

Figure 3 - Unselect Use Senquip Data Format

<b>Document Number</b> APN0016	<b>Revision</b> 1.1	<b>Prepared By</b> NGB	<b>Approved By</b> NB
<b>Title</b> Connecting Senquip Devices to Cumulocity IoT			<b>Page</b> 4 of 8

There is no configuration required in the Cumulocity IoT platform. Devices will be created as they first communicate.

### 3. Creating the Static Templates to Create a Device

To ease device integration, Cumulocity IoT already supports a number of static templates that can be used by any client without the need to create your own templates. These templates focus on the most commonly used messages for device management purposes. These templates will be generated using a script that runs on the Senquip device.


A [list of static templates](#) is shown in Figure 4.



Figure 4 - Available Static Templates.

Messages that are used for device setup are known as [Inventory Templates](#) and are all in the 100's range. These messages set up the device and specify hardware and firmware settings. They only need to be sent once or if there is a change. In the example script, the setup messages are programmed to be sent when the user presses a trigger button on the Senquip Portal, causing a setup function in the script to execute. Device details such as the device name and firmware revision can be read from within a script using the `Cfg.get()` instruction. For further details on setting up trigger buttons on the Senquip Portal and other scripting features, see the [Senquip Scripting Guide](#).

<b>Document Number</b> APN0016	<b>Revision</b> 1.1	<b>Prepared By</b> NGB	<b>Approved By</b> NB
<b>Title</b> Connecting Senquip Devices to Cumulocity IoT			<b>Page</b> 5 of 8



The screenshot shows the Senquip Portal interface. At the top, there is a navigation bar with the Senquip logo, the word 'Portal', and links for 'Upgrade', 'Docs', 'Account', and 'Logout'. Below this is a breadcrumb trail 'Devices / SenquipDemo: Data' and user information 'ADMIN' and 'Premium'. The main content area is titled 'SenquipDemo' and includes a 'Last Contact: a few seconds ago' message. There are two buttons: 'Settings' and 'Raw Data'. A data refresh bar shows 'Latest Data: 22-Sep-21 16:26:34'. Below this are three panels: 'Triggers' with a 'Configure' button, 'Events' showing 'No Events', and 'Device Info' with the following details:


<b>Device ID:</b>	YK3BGCJQ1
<b>Model:</b>	ORB-C1-H
<b>Firmware:</b>	SFW001-4.0.0-rc1
<b>Base Interval:</b>	5 seconds
<b>Wifi IP:</b>	192.168.0.126
<b>Wifi Signal:</b>	-67 dBm

Figure 5 - Trigger button to execute device setup

To create a new device on Cumulocity IoT, we use the 100 template. The format of this message is “100,device name,device type”. The line in the example script to send the 100 template looks like this:

```
MQTT.pub("s/us","100,"+Cfg.get('device.name')+","c8y_MQTTdevice");
```

In this line of code, MQTT.pub publishes the given message to topic “s/us”. Once this message is published, a device will be created on your Cumulocity IoT dashboard.



The screenshot shows the Cumulocity IoT dashboard. On the left is a navigation menu with options: Home, Devices, Registration, All devices, Map, Service monitoring, Overviews, Groups, Device types, and Management. The main area shows 'All devices Showing 1 of 1' with a 'Clear filters' button. Below is a table with the following data:

STATUS	NAME	MODEL	SERIAL NUMBER	GROUP	REGISTRATION DATE
	SenquipDemo	ORB-C1-H	YK3BGCJQ1		20 Sep 2021, 16:52:01

Figure 6 - Device Created on Cumulocity IoT

Document Number	Revision	Prepared By	Approved By
APN0016	1.1	NGB	NB
Title			Page
Connecting Senquip Devices to Cumulocity IoT			6 of 8

We send further configuration messages of type 110, 115, and 117 to send the device ID, model, hardware revision, and firmware revision. Multiple static templates can be published at once by putting them on new lines (\r\n). The entire function, that is executed when the trigger button is pressed is shown in Figure 7.

```
// This function gets called when the user presses the trigger 1 button
SQ.set_trigger_handler(function(trig) {
  if (trig === 1) {
    // Send setup messages (only required once)
    MQTT.pub("s/us", "100,"+Cfg.get('device.name')+",c8y_MQTTdevice\r\n"+
      "110,"+Cfg.get('device.id')+", "+Cfg.get('device.model')+", "+Cfg.get('device.hw')+"\r\n"+
      "115,"+Cfg.get('device.fw')+"\r\n"+
      "117,60");
  }
}, null);
```

Figure 7 - Script to Configure a Device

#### 4. Creating the Static Templates to Send Data and Create Alarms

In this example, we have turned on the GPS and ambient temperature sensors on the Senquip device and are going to send these along with other data to our Cumulocity IoT dashboard. Again we use static templates to send data. The [Measurement Templates](#) are all in the 200's range. In the snippet of code in Figure 8, we are sending location using template 112, temperature using 211, and battery voltage using 212.

```
MQTT.pub("s/us", "100,"+Cfg.get('device.name')+",c8y_MQTTdevice\r\n"+
  "112,"+JSON.stringify(obj.gps_lat)+"", "+JSON.stringify(obj.gps_lon)+"\r\n"+
  "211,"+JSON.stringify(obj.ambient)+"\r\n"+
  "212,"+JSON.stringify(obj.vin));
```

Figure 8 - Sending Data with a Script

We have also created an alarm if the ambient temperature increases above 25 degrees. Alarms are created using [Alarm Templates](#) in the 300's range.

The script to send the measurements and process alerts is in a function that runs after each device measurement cycle and so data will be sent at the Senquip device base interval.

```
// Set an arbitrary alert
if (obj.ambient > 25) {
  let now = Timer.now();
  MQTT.pub("s/us", "301,c8y_TemperatureAlarm,Yikes it is hot in here,"+Timer.fmt("%FT%TZ", now));
}
```

In the Device Manager on Cumulocity IoT we can see the location, battery voltage, an alarm and other information is being shown on a dashboard.




Figure 9 - Data Arriving on Cumulocity IoT

The dashboard shown in Figure 9 has been achieved with no setup of Cumulocity IoT at all. The next step is to use the Cockpit function to manage your device, create dashboards, and explore your data.

## 5. Conclusion

Sending data to Cumulocity IoT is as simple as configuring the Endpoint settings on the Senquip Device and writing a simple script. Almost no configuration is required on Cumulocity IoT as devices are created automatically.

## Appendix 1: Source Code

```
load('senquip.js');
load('api_config.js');
load('api_endpoint.js');
load('api_timer.js');

// This function gets called every time a measurement cycle finishes
SQ.set_data_handler(function(data) {
  let obj = JSON.parse(data);

  // Send some data
  if ((typeof obj.gps_lat === 'number') && (typeof obj.gps_lon === 'number')) {
    MQTT.pub("s/us", "100,"+Cfg.get('device.name')+",c8y_MQTTdevice\r\n"+
      "112,"+JSON.stringify(obj.gps_lat)+", "+JSON.stringify(obj.gps_lon)+"\r\n"+
      "211,"+JSON.stringify(obj.ambient)+"\r\n"+
      "212,"+JSON.stringify(obj.vin));
  }

  // If running off cellular, send details
  if (typeof obj.gsm_imei === 'string') {
    MQTT.pub("s/us", "111,"+JSON.stringify(obj.gsm_imei)+", "+JSON.stringify(obj.gsm_iccid));
  }

  // Set an arbitrary alert
  if (obj.ambient > 25) {
    let now = Timer.now();
    MQTT.pub("s/us", "301,c8y_TemperatureAlarm,Yikes it is hot,"+Timer.fmt("%FT%TZ", now));
  }

}, null);

// This function gets called when the user presses the trigger 1 button
SQ.set_trigger_handler(function(trig) {
  if (trig === 1) {
    // Send setup messages (only required once)
    MQTT.pub("s/us", "100,"+Cfg.get('device.name')+",c8y_MQTTdevice\r\n"+
      "110,"+Cfg.get('device.id')+", "+Cfg.get('device.model')+", "+Cfg.get('device.hw')+"\r\n"+
      "115,"+Cfg.get('device.fw')+"\r\n"+
      "117,60");
  }
}, null);
```